THE MEDICAL UNIVERSITY OF GDAŃSK

THE DEPARTMENT OF HEALTH SCIENCES with a Nursing Division and the Institute of Maritime and Tropical Medicine

THE ENVIRONMENTAL TOXICOLOGY ESTABLISHMENT

ul. Dębowa 23

80-204 GDAŃSK

Tel./Fax 58 34919 37 e-mail: zts@gumed.edu.pl

322/826/326/2014

Gdańsk, on 18-11-2014

HYGIENIC CERTIFICATE No. 307/322/326/2014

1.	**Product (material)**	**Fibreboard MDF/HDF** thickness range: 2.0÷60.0 mm
2.	**Intended purpose**	for the manufacture of furniture and interior design
3.	**The party applying for the assessment of the product**	KRONOSPAN Szczecinek Sp. z o.o. ul. Waryńskiego 1 78-400 78-402 Szczecinek
4.	**Manufacturer**	KRONOSPAN Szczecinek Sp. z o.o. ul. Waryńskiego 1, 78-400 Szczecinek

5. The Products complies with the hygienic requirements , provided that the following conditions are fulfilled:

- The material specific application rate of 0.6 m^2/m^3 of the volume of: residential spaces; spaces designed for a permanent stay of patients at healthcare facilities; spaces for children and the youth at educational buildings; and spaces designed for storing foodstuffs;
- The material specific application rate of 1.2 m^2/m^3 of the volume of: public buildings other than those specified herein above; and ancillary rooms at homes.

The Certificate does not concern the health and safety-at-work requirements while installing the Product. Spaces in which the aforesaid Product has been installed should be ventilated until its smell is gone.

6. The regulatory basis for the issuance of the Certificate: the letter OB-RPPD Sp. z o.o. BW/452/1057/14 of 24-10-2014; Test report No. 5029/12/2014 of 24-10-2014 issued by the Product Testing Laboratory at the Research and Development Centre of the Engineered Wood Panel Industry: Laboratorium Badania Wyrobów Ośrodka Badawczo-Rozwojowego Przemysłu Płyt Drewnopochodnych Sp. z o.o. w Czarnej Wodzie.
Hygienic Class E-1.

7. The Certificate may be amended or annulled once relevant evidence has been produced by either of the parties. This Certificate shall be null and void 5 years of the date of its issue or in case of changes to the recipe or manufacture technology of the Products.

Stamped and signed:
MANAGER
Environmental Toxicology Establishment
prof. dr hab. Lidia Wolska

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

I, Maciej Śpiewak, hereby certify, as a sworn interpreter and translator of the English language that this is a translation of the document in Polish submitted to me. This translation has been done in Dobra, on 27 November, 2014. Pages: 1. Reg. No. 476/2014.

Sworn translator
Maciej Śpiewak

M. Śpiewak

MACIEJ ŚPIEWAK TŁUMACZ PRZYSIĘGŁY JĘZYKA ANGIELSKIEGO NR TP-507/05