

Damixa Space, 1-handle basin mixer

Holder/Issued to

FM Mattsson Mora Group Danmark ApS

Hvidkærvej 48, 5250 Odense SV, Denmark

Organisation number: 56416218

Tel: +45 8833 00 34

E-mail: danmark@fmm-mora.com Web: www.damixa.com

Product description

Damixa Space and Primola 1-handle mixer, for washbasins with or without pop-up waste valve. The mixers have adjustable flow restrictor and temperature lock. Mixers are supplied with flexible connection hoses that are covered by Swedish technical approval and have connection G 3/8".

Intended use

Single handle mixer intended for drinking water.

Trade name

1-handle basin mixer,
Damixa Space, Damixa no. 100210000.
Damixa Space Rehab, Damixa no. 104210000.
Damixa Space with pop up waste valve, Damixa no. 108210000.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations	6:62,	1 st sentence and 2 nd paragraph and general recommendation
Tap water flow	6:623	1 st sentence
Design	6:625,	1 st and 4 th paragraph

Associated documents


Installation instruction Damixa, version 08.14 - 20026.00.
User instruction Damixa, version 12.06 - 12676.00.

Type approval SC0703-17 | 2021-03-16

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Tel: +46 10-516 50 00
certifiering@ri.se | www.ri.se



2P02872 (7P03009)



Page 1 (3)

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 210-17-0103. Inspection body: RISE Research Institutes of Sweden AB.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

Manufacturing place

Production controls include the following places:
FM Mattsson Mora Group Danmark ApS Odense and production site 912350.

Marking

The products are to be marked at the factory.
The marking consists of a text on every product and packing and includes:

Distributor*
Boverket's registered trade mark
Certification body and accreditation number
Type approval number
Product type designation
Consecutive manufacture year and month*
Inspection body

Damixa
†
RISE Certifiering 1002
SC0703-17
trade name
yy.mm
RISE

*text on mixer

Basis for approval

Report 5351382-01 from LGA, Germany.
Report 289853C from DTI, Danish Technological Institute.
Report 392-2016-00464001 from Eurofins, Denmark.

Comments

Mixers are approved in accordance with SS-EN 817.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.
Group 1: max 20dB (A) Lap at 0,3 MPa.
Group 2: max 30dB (A) Lap at 0,3 MPa.
Group 3: not classified.

The mixers are classified in group 1.

This approval supersedes the previous approval with the same number dated 2017-06-15.

Validity

Valid through 2022-06-14.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.